



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Technical Construction Infrastructure Inc.
4181 Sladeview Cres.
Unit #32
Mississauga, Ontario L5L 5R2, Canada

Plant Location:

Mississauga, Ontario, Canada

Standards:

NSF/ANSI/CAN 61 - 2022

Certificate:

Issued Date: 09/06/2023

Material/Product:

Structural Strengthening Liner

Contact Temperature:

23 ± 2°C

Models:

TCI CarbonStrong 850



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 36

Maximum pipe surface area/volume ratio (sq in/L): 6.8

Minimum tank size (gallons): 2000

Maximum tank surface area/volume ratio (sq in/L): 4.5

Maximum dry film thickness per coat (mils): Multiple coats, max thickness total= 750mils

Number of coats: Please refer to manufacturing recommendations

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 24 hours/ 23

Shortest cure time between coats or layers: 48 hours

Final cure time: 72 hours

Mix ratio: Please refer to manufacturing recommendations

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): No

Additional comments:

The coating is a system of 5 components, which consists of a primer: TCI 800-D (5 to 7 Mils), Tack coat: TCI 200-B (20 Mils), 2 layers of GFRP fabric saturated with TCI 300-S (80 Mils), 10 layers of CFRP fabric saturated with TCI 300-S (600 Mils), and a Top coat: ShieldStrong 955(40 Mils).



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.