

ALS Group USA, Corp.

3337 Michelson Drive, Suite CN750, Irvine, CA 92612

Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Technical Construction Infrastructure Inc. 4181 Sladeview Cres. Unit #32 Mississauga, Ontario L5L 5R2, Canada

Plant Location:

Mississauga, Ontario, Canada

Standards:

NSF/ANSI/CAN 61 - 2020

Certificate:

Issued Date: 09/29/2022

Material/Product:

Protective Coating.

Contact Temperature:

23 ± 2°C

Models:

ShieldStrong 955







ALS Group USA, Corp.

3337 Michelson Drive, Suite CN750, Irvine, CA 92612

Material Characteristics:

Minimum pipe diameter (inches): 20

Maximum pipe surface area/volume ratio (sq in/L): 12.2

Minimum tank size (gallons): 1000

Maximum tank surface area/volume ratio (sq in/L): 5.7

Maximum dry film thickness per coat (mils): 80

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Total cure time and temperature: 72 hours @ 23°C

Shortest cure time between coats or layers: 24 Hours

Final cure time: 72 Hours

Mix ratio: 1:2 by Weight (1 Hardener, 2 Resin)

Colors: Blue

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes

Additional comments:

Multiple layers may be used as long as the total thickness does not exceed 80 mils.



